

IEC 61850 Certificate - IEC 61850 Certificate #2465

REC670 Bay Control [ABB AB]

07/08/2021 04:40 PM - Herbert Falk

Status:	Approved	Certificate Name:	1KHL050078
Priority:	Normal	Certificate Hash:	6E0383C35334DCD31654057F3330A2 DDC016EF0446A526269A981F9811280 C65
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	ABB AB	Umbrella Organization:	
Address:	SA Products S-721 59 Vasteras Sweden	Optional Reservation Test:	No
Product:	REC670 Bay Control	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	2.1	Publisher Preferred Rates:	
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	2.3	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	01/01/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	ABB Switzerland Ltd. (B)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:40 PM - Herbert Falk

- File 1KHL050078_IEC61850Ed1ConformanceCertificate_TPCL1.8_REC670_added

Files

1KHL050078_IEC61850Ed1ConformanceCertificate_TPCL1.8_REC670_27MB

07/08/2021

Herbert Falk