

IEC 61850 Certificate - IEC 61850 Certificate #2468

PCS-9799 [NR Electric Co., Ltd.]

07/08/2021 04:41 PM - Herbert Falk

Status:	Approved	Certificate Name:	74108090-OPE/INC 15-2506
Priority:	Normal	Certificate Hash:	8DC468F824E1D9A1BC58A6E1356100 1B982263BA7601135C29A6B6B6ADAA 208F
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Client	Vendor Artifact Hash:	
Company:	NR Electric Co., Ltd.	Umbrella Organization:	
Address:	69, Suyuan Avenue Nanjing 211102 China	Optional Reservation Test:	Yes
Product:	PCS-9799	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	3.50	Publisher Preferred Rates:	
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	01/03/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:41 PM - Herbert Falk

- File 15-2506_DNVGL_NR-Electric_PCS-9799_ClientEd2_Certificate.pdf added

#2 - 07/11/2021 10:06 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

15-2506_DNVGL_NR-Electric_PCS-9799_ClientEd2_Certificate.pdf 2.89 MB

07/08/2021

Herbert Falk