

IEC 61850 Certificate - IEC 61850 Certificate #2469

PCS-9611 [NR Electric Co., Ltd.]

07/08/2021 04:41 PM - Herbert Falk

Status:	Approved	Certificate Name:	74108090-OPE/INC 15-2503
Priority:	Normal	Certificate Hash:	66C840CAF930E9DA51C05D5B11728D 49559F47C60C480C6A6A83350E211C 8327
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	NR Electric Co., Ltd.	Umbrella Organization:	
Address:	69 Suyuan Avenue 211102 Nanjing China	Optional Reservation Test:	No
Product:	PCS-9611	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	1.00	Publisher Preferred Rates:	
Key Words:	Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	01/03/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:41 PM - Herbert Falk

- File 15-2503_DNVGL_NR-Electric_PCS-9611_PCS-9000variants_ServerEd added

Files

15-2503_DNVGL_NR-Electric_PCS-9611_PCS-9000variants_ServerEd	1.1 MB	07/08/2021	Herbert Falk
--	--------	------------	--------------