

IEC 61850 Certificate - IEC 61850 Certificate #2470

SEL-751 [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:41 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10011514-OPE/INC 15-3067
61850 Edition:	Edition 2	Certificate Hash:	3D8A783A13368FEE1B46B1DD59EA9A 375464B4BFB15E55F57620E82FBA776 091
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact Hash:	
Address:	2350 NE Hopkins Court Pullman, WA 99163 USA	Umbrella Organization:	
Product:	SEL-751	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	R111	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	01/23/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:41 PM - Herbert Falk

- File 15-3067_DNVGL_SEL-751_ServerEd2_Certificate.pdf added

Files

15-3067_DNVGL_SEL-751_ServerEd2_Certificate.pdf	2.78 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------