

IEC 61850 Certificate - IEC 61850 Certificate #2472

Enilit RTU [UAB "Enilit"]

07/08/2021 04:41 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10010305-OPE/INC 15-3064
61850 Edition:	Edition 2	Certificate Hash:	E8CB5FCC94BD866DB871E55A122FBC291FFBAD4FD5DD9F4A71714F864E0E080C
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	UAB "Enilit"	Vendor Artifact Hash:	
Address:	Veiveriu str. 134-221 LT-46352 Kaunas Lithuania	Umbrella Organization:	
Product:	Enilit RTU	Optional Reservation Test:	Yes
HW Version:		Serial Number:	
SW Version:	4.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	01/23/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:41 PM - Herbert Falk

- File 15-3064_DNVGL_Enilit_RTU_ClientEd2_Certificate.pdf added

#2 - 07/11/2021 10:06 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

15-3064_DNVGL_Enilit_RTU_ClientEd2_Certificate.pdf	2.02 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------