

IEC 61850 Certificate - IEC 61850 Certificate #2474

F650 [GE Multilin]

07/08/2021 04:41 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74108094-OPE/INC 16-0008
61850 Edition:	Edition 2	Certificate Hash:	45666DBEBCC5540A75E729C92053E3 FEE011C2B400CF8CF3E4CF993AEA1 F67B2
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Multilin	Vendor Artifact Hash:	
Address:	650 Markland St. Markham, ON L6C 0M1 Canada	Umbrella Organization:	
Product:	F650	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	7.20	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	01/23/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:41 PM - Herbert Falk

- File 16-0008_DNV-GL_Certificate_GE_F650_ServerEd2_(TPCL1p0p2).pdf added

Files

16-0008_DNV-GL_Certificate_GE_F650_ServerEd2_(TPCL1p0p2).pdf .99 MB

07/08/2021

Herbert Falk