

IEC 61850 Certificate - IEC 61850 Certificate #2480

PowerLogic ION7400 Meter [Schneider Electric]

07/08/2021 04:41 PM - Herbert Falk

Status:	Approved	Certificate Name:	10010289-OPE/IN 16-0005
Priority:	Normal	Certificate Hash:	F3CF86E78C729D1D0C0134C0853CF0 24A372B5FC639ED76226AC3CBD8D3 7CC0A
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric	Umbrella Organization:	Schneider Electric
Address:	2195 Keating Cross Road Saanichton, British Columbia Canada V8M 2A5	Optional Reservation Test:	No
Product:	PowerLogic ION7400 Meter	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	001.002.015	Publisher Preferred Rates:	
Key Words:	Meter	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	01/31/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:41 PM - Herbert Falk

- File 16-0005_DNVGL_Schneider_ION7400_PM8000_ServerEd2_Certificate added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

16-0005_DNVGL_Schneider_ION7400_PM8000_ServerEd2_Certificate.pdf	162 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------