

IEC 61850 Certificate - IEC 61850 Certificate #2481

REF620 [ABB OY]

07/08/2021 04:41 PM - Herbert Falk

<b>Status:</b>	Approved	
<b>Priority:</b>	Normal	
<b>61850 Edition:</b>	Edition 1	<b>Certificate Name:</b> 74108008-OPE/INC 15-2323 Rev. 1
<b>61850 Tested Aspects:</b>	Server	<b>Certificate Hash:</b> CDDE4699BE1EBB4413A9FA526359006F9D4EE33BAC4D2AD482BDC0053CA9B58F
<b>Company:</b>	ABB OY	<b>Vendor Artifact File Name:</b>
<b>Address:</b>	Medium Voltage Products Muottitie 2 FI-65101 Vaasa Finland	<b>Vendor Artifact Hash:</b>
<b>Product:</b>	REF620	<b>Umbrella Organization:</b>
<b>HW Version:</b>	G	<b>Optional Reservation Test:</b> No
<b>SW Version:</b>	2.1	<b>Serial Number:</b>
<b>Key Words:</b>	Protection, Relay	<b>Publisher Legacy Variants:</b>
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Rates:</b>
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Publisher Preferred Variants:</b>
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Legacy Variants:</b>
<b>Approval Date:</b>	01/31/2016	<b>Subscriber Preferred Variants:</b>
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	<b>Subscriber Preferred Rates:</b>
<b>Current Test Lab Name:</b>	DNV Netherlands (A)	<b>Product Variants:</b>
<b>Test Document:</b>		
<b>Description</b> This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:41 PM - Herbert Falk  
- File 15-2323Rev1\_DNVGL\_ABB\_REF620\_REM620\_RET620\_ServerEd1\_Certifi added

Files

15-2323Rev1_DNVGL_ABB_REF620_REM620_RET620_ServerEd1_Certifi.pdf	07/08/2021	Herbert Falk
--	------------	--------------