

IEC 61850 Certificate - IEC 61850 Certificate #2484

MiCOM P40 Agile P145 [Alstom Grid UK Ltd.]

07/08/2021 04:41 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6145.802
61850 Edition:	Edition 2	Certificate Hash:	0621AC83EA3E946DAD979E787FB78C E516519B9CA33425EE8D0AFE0E61C 1726
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Alstom Grid UK Ltd.	Vendor Artifact Hash:	
Address:	St. Leonards Avenue Stafford, ST17 4LX United Kingdom	Umbrella Organization:	
Product:	MiCOM P40 Agile P145	Optional Reservation Test:	No
HW Version:	M	Serial Number:	
SW Version:	61A	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	02/06/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:41 PM - Herbert Falk

- File 50745.6145.802_ALSTOM_MiCOM_P140_Edition2_Certificate.pdf added

#2 - 08/04/2021 09:37 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6145.802_ALSTOM_MiCOM_P140_Edition2_Certificate.pdf 1.62 MB 07/08/2021 Herbert Falk