

IEC 61850 Certificate - IEC 61850 Certificate #2485

DW-SPiN [Daewoong Electric Co. Ltd.]

07/08/2021 04:41 PM - Herbert Falk

| | | | |
|--|--|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 16-000029-02 |
| 61850 Edition: | Edition 1 | Certificate Hash: | 9DF9B7062E37C2E8DDC4502255D6A3 D6FFC68765DB0CA2D22D64821E0528 99FD |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | Daewoong Electric Co. Ltd. | Vendor Artifact Hash: | |
| Address: | 10, Hwanggeum-ro 127beon-gil, Yangchon-eup. Gimpo-si, Gyeonggi-do, Republic of Korea, 10048 | Umbrella Organization: | |
| Product: | DW-SPiN | Optional Reservation Test: | No |
| HW Version: | | Serial Number: | |
| SW Version: | 1.0 | Publisher Legacy Variants: | |
| Key Words: | | Publisher Preferred Rates: | |
| Test Procedure Version: | 3.02 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | kathy.ellis,bruce.muschlitz | Subscriber Preferred Variants: | |
| Approval Date: | 02/06/2016 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | Korea Testing Laboratory (A) | | |
| Description | | | |
| This certificate and its information was migrated from a previous database | | | |

History

#1 - 07/08/2021 04:41 PM - Herbert Falk

- File [160126] Daewoong_Certificate_Server_Ed1_Revision_3p02_KTL.p added

Files

[160126] Daewoong_Certificate_Server_Ed1_Revision_3p02_KTL.pdf 147 KB

07/08/2021

Herbert Falk