

IEC 61850 Certificate - IEC 61850 Certificate #2491

Siprotec 5 7SL82 [Siemens AG, EM DG PRO]

07/08/2021 04:42 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74108226-OPE/INC 16-0015
61850 Edition:	Edition 2	Certificate Hash:	D9AD5F4B21656111DFDE18FEBF6825 F2FF1F31D3B68A65471BD1028E2121 F44F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens AG, EM DG PRO	Vendor Artifact Hash:	
Address:	Wernerwerkdammm 5 13629 Berlin Germany	Umbrella Organization:	
Product:	Siprotec 5 7SL82	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	07.00	Publisher Legacy Variants:	
Key Words:	Differential, Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	02/06/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:42 PM - Herbert Falk

- File 16-0015_DNVGL_SIEMENS_7SL82_7SA82_7SD82_7UT82_ServerEd2_Certificate.pdf added

Files

16-0015_DNVGL_SIEMENS_7SL82_7SA82_7SD82_7UT82_ServerEd2_Certificate.pdf 07/08/2021

Herbert Falk