

IEC 61850 Certificate - IEC 61850 Certificate #2492

TAPCON Voltage Regulator Unit [Maschinenfabrik Reinhausen GmbH]

07/08/2021 04:42 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	1KHL050084
61850 Edition:	Edition 1	Certificate Hash:	9DFF6D9CFDDB973399A7F60D8F6B1 B5BAFEB3C58693D68F5F45FEE1459E ABF7D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Maschinenfabrik Reinhausen GmbH	Vendor Artifact Hash:	
Address:	Falkensteinstr. 8 93059 Regensburg	Umbrella Organization:	
Product:	TAPCON Voltage Regulator Unit	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.02	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Buffered Reporting (B6+), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	02/19/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	ABB Switzerland Ltd. (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:42 PM - Herbert Falk

- File 1KHL050084_IEC61850ConformanceCertificate_ServerEd1_Tapcon_v added

Files

1KHL050084_IEC61850ConformanceCertificate.pdf_ServerEd1_Tapcon_vMB

07/08/2021

Herbert Falk