

# IEC 61850 Certificate - IEC 61850 Certificate #2496

## CSC-300 [Beijing Sifang Automation Co., Ltd.]

07/08/2021 04:42 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	2016PUCA0004
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	7DA97AB51BA4782B336D04BCCC245 D0E7EB309142B5FF8BD2D6DCE43D1 3E75FE
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Beijing Sifang Automation Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	No. 9, Shangdi 4th Street, Haidian District, Beijing, P.R. China	<b>Umbrella Organization:</b>	
<b>Product:</b>	CSC-300	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	1.00MYS	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	02/27/2016	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Xuchang KETOP Testing Research Institute Co.(A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:42 PM - Herbert Falk

- File BEIJING\_SIFANG\_CSC-300\_V1.00MYS\_Numerical Generator Transfor added

### Files

BEIJING\_SIFANG\_CSC-300\_V1.00MYS\_Numerical Generator Transfor.dmp

07/08/2021

Herbert Falk