

IEC 61850 Certificate - IEC 61850 Certificate #2500

MicroSCADA Pro SYS600 [ABB OY]

07/08/2021 04:42 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 74108538-OPE/INC 15-3170
61850 Tested Aspects:	Client	Certificate Hash: FD4BB4ED9D751BCB63231C049453F3 E00FD5F192050592088231573A81DD1 997
Company:	ABB OY	Vendor Artifact File Name:
Address:	Grid Automation Products Virtavilva 9 A 65101 VAASA Finland	Vendor Artifact Hash:
Product:	MicroSCADA Pro SYS600	Umbrella Organization:
HW Version:	3.94	Optional Reservation Test: No
SW Version:	9.4	Serial Number:
Key Words:		Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	02/27/2016	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:42 PM - Herbert Falk

- File 15-3170_DNVGL_ABB_SYS600_ClientEd2_Certificate-1.pdf added

Files

