IEC 61850 Certificate - IEC 61850 Certificate #2505

889 Generator Protection Sys. [GE Multilin]

07/08/2021 04:42 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	74108094-OPE/INC 16-1750
61850 Tested Aspects:	Server	**Certificate Hash:**	354F914AE15762C0CF46E1AF2859FB45719A29ED94784800B69BB58100BE00E5
Company:	GE Multilin	**Vendor Artifact File Name:**	
Address:	650 Markland St. Markham, ON L6C 0M1 Canada	**Vendor Artifact Hash:**	
Product:	889 Generator Protection Sys.	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	1.60	**Serial Number:**	
Key Words:	Protection	**Publisher Legacy Variants:**	
Test Procedure Version:	1.0	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	kathy.ellis	**Subscriber Legacy Variants:**	
Approval Date:	03/28/2016	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:42 PM - Herbert Falk

- File 16-1750_DNVGL_GE-MULTILIN_889_ServerEd2_Certificate.pdf added

Files

16-1750_DNVGL_GE-MULTILIN_889_ServerEd2_Certificate.pdf	1.93 MB	07/08/2021	Herbert Falk