

IEC 61850 Certificate - IEC 61850 Certificate #2505

889 Generator Protection Sys. [GE Multilin]

07/08/2021 04:42 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	74108094-OPE/INC 16-1750
61850 Edition:	Edition 2	Certificate Hash:	354F914AE15762C0CF46E1AF2859FB 45719A29ED94784800B69BB58100BE0 0E5
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Multilin	Vendor Artifact Hash:	
Address:	650 Markland St. Markham, ON L6C 0M1 Canada	Umbrella Organization:	
Product:	889 Generator Protection Sys.	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.60	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	03/28/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:42 PM - Herbert Falk

- File 16-1750_DNVGL_GE-MULTILIN_889_ServerEd2_Certificate.pdf added

Files

16-1750_DNVGL_GE-MULTILIN_889_ServerEd2_Certificate.pdf	1.93 MB	07/08/2021	Herbert Falk
---------------------------------------------------------	---------	------------	--------------