

IEC 61850 Certificate - IEC 61850 Certificate #2510

GRL200 [TOSHIBA Corporation]

07/08/2021 04:43 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10010206-OPE/INC 16-1709
61850 Tested Aspects:	Server	Certificate Hash: 24E345DEF66920E51396B4C0721E73 A7D95F85EA6CC65B856BD1D736F603 4BD5
Company:	TOSHIBA Corporation	Vendor Artifact File Name:
Address:	Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-shi, Tokyo, 183-8511	Vendor Artifact Hash:
Product:	GRL200	Umbrella Organization:
HW Version:	GRL200-11-234-21-33-31-110	Optional Reservation Test: No
SW Version:	GS2RLIM13006	Serial Number:
Key Words:	Differential, Protection	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	04/16/2016	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:43 PM - Herbert Falk

- File 16-1709_DNVGL_TOSHIBA_GRL200_ServerEd2_Certificate.pdf added

Files

16-1709_DNVGL_TOSHIBA_GRL200_ServerEd2_Certificate.pdf	2.85 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------