

IEC 61850 Certificate - IEC 61850 Certificate #2512

INGEPAC DA-PT [Ingeteam Power Technology, S.A.]

07/08/2021 04:43 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 84000028-OPE/INC 16-0018
61850 Tested Aspects:	Server	Certificate Hash: F06FF2B5DB06F6AD715EDF1DD8DB051D45BA2D48822A0E69B26292FEB25D6F39
Company:	Ingeteam Power Technology, S.A.	Vendor Artifact File Name:
Address:	Power Grid Automation - PGA Parque Tecnológico de Bizkaia, Edificio 110 48170 Zamudio, Bizkaia Spain	Vendor Artifact Hash:
Product:	INGEPAC DA-PT	Umbrella Organization:
HW Version:	PT1BDBCCFFFAAMAPXXXX	Optional Reservation Test: No
SW Version:	0.5.1.0	Serial Number:
Key Words:	Protection	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	04/16/2016	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:43 PM - Herbert Falk

- File 16-0018_DNVGL_Ingeteam_INGEPAC_DA-PT_ServerEd2_Certificate.p added

Files

