

IEC 61850 Certificate - IEC 61850 Certificate #2513

CFP1-A41D1 [Mitsubishi Electric Corporation]

07/08/2021 04:43 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10013608-OPE/INC 16-1735
61850 Edition:	Edition 1	Certificate Hash:	448458E86897B1C50AF11E21D1703E DB1EB1185782B21F1B1BFD7C241751 4896
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Mitsubishi Electric Corporation	Vendor Artifact Hash:	
Address:	1-1-2 Wadasaki-Cho, Hyogo-ku 652-8555 Kobe Japan	Umbrella Organization:	
Product:	CFP1-A41D1	Optional Reservation Test:	No
HW Version:	405PQB	Serial Number:	
SW Version:	PGKK0304	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.03	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	04/16/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:43 PM - Herbert Falk

- File 16-1735_DNVGL_Mitsubishi_CFP1-A41D1_ServerEd1_Certificate.pd added

Files

16-1735_DNVGL_Mitsubishi_CFP1-A41D1_ServerEd1_Certificate.pd 2.62 MB

07/08/2021

Herbert Falk