

IEC 61850 Certificate - IEC 61850 Certificate #2515

P546 [Schneider Electric]

07/08/2021 04:43 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 74104410-OPE/INC 16-1778
61850 Tested Aspects:	Server	Certificate Hash: C0BD997DF594E7BE7D33FB36280CA E5C9607CF7C0AA7E3912B4BA19E7A E4237B
Company:	Schneider Electric	Vendor Artifact File Name:
Address:	35 rue Joseph Monier 92500 Reuil Malmaison France	Vendor Artifact Hash:
Product:	P546	Umbrella Organization: Schneider Electric
HW Version:	M	Optional Reservation Test: No
SW Version:	H4	Serial Number:
Key Words:	Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	04/26/2016	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:43 PM - Herbert Falk

- File 16-1778_DNVGL_SchneiderElectric_P546_ServerEd2_Certificate.p added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

