

IEC 61850 Certificate - IEC 61850 Certificate #2516

MiCOM C264 [Schneider Electric]

07/08/2021 04:43 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10007589-OPE/INC 16-1894
61850 Tested Aspects:	Server	Certificate Hash: 58E28D8AD3A3973590DA5B2F4FD82632177746AFAB16AB46E458E8385E379088
Company:	Schneider Electric	Vendor Artifact File Name:
Address:	Avenue de Figuières 34975 Lattes France	Vendor Artifact Hash:
Product:	MiCOM C264	Umbrella Organization: Schneider Electric
HW Version:		Optional Reservation Test: No
SW Version:	D2.06	Serial Number:
Key Words:		Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	04/26/2016	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:43 PM - Herbert Falk

- File 16-1894_DNVGL_SchneiderElectric_C264_ServerEd2_Certificate.p added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

16-1894_DNVGL_SchneiderElectric_C264_ServerEd2_Certificate.pdf2.56 MB

07/08/2021

Herbert Falk