

# IEC 61850 Certificate - IEC 61850 Certificate #2517

## SWCLS201 [Korea Electric Power Corporation]

07/08/2021 04:43 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	2016TS01084
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	FC9F2B29EC17F39EFE4D0D9C330B4 2C0BB601E7AC9325F0C271864DF71C F30BE
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	Korea Electric Power Corporation	<b>Umbrella Organization:</b>	
<b>Address:</b>	105 Munji-Ro, Yuseong-Gu, Daejeon, 34056, Republic of Korea	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	SWCLS201	<b>Serial Number:</b>	
<b>HW Version:</b>		<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	14.04	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	04/26/2016	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Test Document:</b>			

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:43 PM - Herbert Falk

- File 2016TS01084\_KEPRI\_SWCLS201\_Server2.0\_KERI.pdf added

### Files

2016TS01084\_KEPRI\_SWCLS201\_Server2.0\_KERI.pdf

2.99 MB

07/08/2021

Herbert Falk