

# IEC 61850 Certificate - IEC 61850 Certificate #2519

## BMRZ-152-KSZ [MECHANOTRONIKA LTD]

07/08/2021 04:43 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	Schneider_VAL_BMRZ-152-KSZ_version-
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	0103D1AE6A205AD7FBFACD0DA23614D4DB0ACAA77EE116F66E5FB9DFB51754CB
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	MECHANOTRONIKA LTD	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Bld. 23 A, str. Pionerstroya St. Petersburg, 198206 - Russia	<b>Umbrella Organization:</b>	
<b>Product:</b>	BMRZ-152-KSZ	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	648228.039-02	<b>Serial Number:</b>	
<b>SW Version:</b>	2.0.1	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	05/03/2016	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Schneider-Electric China (B)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:43 PM - Herbert Falk

- File Schneider\_VAL\_BMRZ-152-KSZ\_version-2.0.1\_Ed2\_Certificate-1.p added

#2 - 07/09/2021 09:16 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#3 - 07/16/2021 06:33 AM - Herbert Falk

- Umbrella Organization deleted (Schneider Electric)

### Files

Schneider\_VAL\_BMRZ-152-KSZ\_version-2.0.1\_Ed2\_Certificate-1.pdf 713 KB

07/08/2021

Herbert Falk