

IEC 61850 Certificate - IEC 61850 Certificate #2522

MiCOM P841 [Schneider Electric Industries SAS]

07/08/2021 04:43 PM - Herbert Falk

Status:	Approved	Certificate Name:	ZE 16 05 89191 007
Priority:	Normal	Certificate Hash:	790F918FD27D3D37854A1868CBA6AA 71C0CC475EF3CD9543571F265B29A6 F32D
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric Industries SAS	Umbrella Organization:	Schneider Electric
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison France	Optional Reservation Test:	No
Product:	MiCOM P841	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	H4	Publisher Preferred Rates:	
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	05/13/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:43 PM - Herbert Falk

- File 16-ZE 16 05 89191 007-Schneider Electric_MiCOM P841_IEC61850 added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

16-ZE 16 05 89191 007-Schneider Electric_MiCOM P841_IEC61850.pdf 7 MB

07/08/2021

Herbert Falk