

IEC 61850 Certificate - IEC 61850 Certificate #2531

MiCOM P40 Agile P14DZ [UK Grid Solutions Limited]

07/08/2021 04:44 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 10010242-OPE/INC 16-2154
61850 Tested Aspects:	Server	Certificate Hash: 3B297FA1CFB9C5E051C6FCF8A45016C49A755C7725EBE650328A994C77CD67E1
Company:	UK Grid Solutions Limited	Vendor Artifact File Name:
Address:	St. Leonards Avenue Stafford ST17 4LX United Kingdom	Vendor Artifact Hash:
Product:	MiCOM P40 Agile P14DZ	Umbrella Organization:
HW Version:	A	Optional Reservation Test: No
SW Version:	56B	Serial Number:
Key Words:	Protection	Publisher Legacy Variants:
Test Procedure Version:	2.3	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis	Subscriber Legacy Variants:
Approval Date:	08/03/2016	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-2154_DNVGL_GE_P40_Agile_P14DZ_variants_ServerEd1_Certific added

Files

16-2154_DNVGL_GE_P40_Agile_P14DZ_variants_ServerEd1_Certificate.pdf	152 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------