

IEC 61850 Certificate - IEC 61850 Certificate #2533

SPPA-T3000 Control System [Siemens AG]

07/08/2021 04:44 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10018078-OPE/INC 16-2040
61850 Edition:	Edition 1	Certificate Hash:	5B7FC31B14E708CB178753EDFE526B D04A5498FE2BE606BD86BD6E9F2361 7800
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Siemens AG	Vendor Artifact Hash:	
Address:	PD PA EA R&D-E Siemensalle 84 76187 Karlsruhe Germany	Umbrella Organization:	
Product:	SPPA-T3000 Control System	Optional Reservation Test:	No
HW Version:	30914/A	Serial Number:	
SW Version:	07.2.11.11	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	08/03/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-2040 DNVGL Siemens - SPPA T3000_ClientEd1_Certificate.pdf added

Files

16-2040 DNVGL Siemens - SPPA T3000_ClientEd1_Certificate.pdf	132 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------