

IEC 61850 Certificate - IEC 61850 Certificate #2537

CSI-200E Bay Control [Beijing Sifang Automation Co., Ltd.]

07/08/2021 04:44 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10017938-OPE/INC 16-1965
61850 Edition:	Edition 2	Certificate Hash:	3EE5A99823860224A4D4BD5EA828C1 F8CA65894594CA4BC98AFF61A59106 4906
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Beijing Sifang Automation Co., Ltd.	Vendor Artifact Hash:	
Address:	No. 9, Fourth Street, Shangdi Information Industry Base Haidian District Beijing 100085 China	Umbrella Organization:	
Product:	CSI-200E Bay Control	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	7.10	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Variants:	
Approval Date:	08/03/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-1965_DNV-GL_Sifang_CSI-200E_ServerEd2_Certificate.pdf added

Files

16-1965_DNV-GL_Sifang_CSI-200E_ServerEd2_Certificate.pdf	137 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------