

IEC 61850 Certificate - IEC 61850 Certificate #2538

REB500 [ABB AB]

07/08/2021 04:44 PM - Herbert Falk

Status:	Approved	Certificate Name:	10016857-OPE/INC 16-2048
Priority:	Normal	Certificate Hash:	D15384B96F45ED56410196AD8A6A81 9542A749EA9536D2FC902E099B88EC BADC
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	ABB AB	Umbrella Organization:	
Address:	Grid Automation Products S-721 59 Vasteras Sweden	Optional Reservation Test:	No
Product:	REB500	Serial Number:	
HW Version:	1MRK010003	Publisher Legacy Variants:	
SW Version:	8.2.0.1	Publisher Preferred Rates:	
Key Words:	Protection	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis	Subscriber Preferred Rates:	
Approval Date:	08/29/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-2048-DNV_GL_ABB_REB500_ServerEd2_Certificate.pdf added

Files

16-2048-DNV_GL_ABB_REB500_ServerEd2_Certificate.pdf	139 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------