

IEC 61850 Certificate - IEC 61850 Certificate #2540

MPM 400.D [Dema Role A.S.]

07/08/2021 04:44 PM - Herbert Falk

| | | | |
|--|---|---------------------------------------|--|
| Status: | Approved | Certificate Name: | 10004271-OPE/INC 16-2130 |
| Priority: | Normal | Certificate Hash: | C002769E653EA9884AA710166330A48 B8F945717185CE40D25F38F45DC77B 727 |
| 61850 Edition: | Edition 2 | Vendor Artifact File Name: | |
| 61850 Tested Aspects: | Server | Vendor Artifact Hash: | |
| Company: | Dema Role A.S. | Umbrella Organization: | |
| Address: | Zumrutevler Mh. Ataturk Cd. Inanc Sk. No: 4 34852 Maltepe, Istanbul Turkey | Optional Reservation Test: | No |
| Product: | MPM 400.D | Serial Number: | |
| HW Version: | | Publisher Legacy Variants: | |
| SW Version: | 1.0 | Publisher Preferred Rates: | |
| Key Words: | Protection, Relay | Publisher Preferred Variants: | |
| Test Procedure Version: | 1.0 | Subscriber Legacy Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Preferred Variants: | |
| Certificate/Result Reviewer: | kathy.ellis | Subscriber Preferred Rates: | |
| Approval Date: | 09/09/2016 | Product Variants: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |
| Test Document: | | | |
| Description | | | |
| This certificate and its information was migrated from a previous database | | | |

History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-2130_DNVGL_DEMA_MPM400D_DPM400D_CPM400D_VPM400D_ServerEd2 added

Files

16-2130_DNVGL_DEMA_MPM400D_DPM400D_CPM400D_VPM400D_ServerEd2.pdf 07/08/2021

Herbert Falk