

IEC 61850 Certificate - IEC 61850 Certificate #2541

MiCOM P746 [Schneider Electric Industries SAS]

07/08/2021 04:44 PM - Herbert Falk

Status:	Approved	Certificate Name:	ZE 16 09 89191 012
Priority:	Normal	Certificate Hash:	C43A9F1B807980E8C20C0BCBA99020 4509B0CA99AA689A20C59231FB677F E543
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric Industries SAS	Umbrella Organization:	Schneider Electric
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison France	Optional Reservation Test:	No
Product:	MiCOM P746	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	C3	Publisher Preferred Rates:	
Key Words:	Protection	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	09/09/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-ZE 16 09 89191 012 Schneider Electric_MiCOM P746C3_IEC618 added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

16-ZE 16 09 89191 012 Schneider Electric_MiCOM P746C3_IEC61850.pdf 1KB

07/08/2021

Herbert Falk