

IEC 61850 Certificate - IEC 61850 Certificate #2542

MiCOM P746 [Schneider Electric Industries SAS]

07/08/2021 04:44 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: ZE 16 09 89191 011
61850 Tested Aspects:	Server	Certificate Hash: D0540C4396A797F6213F7A13F28411B7800AF9585DEBDB6E23A8AADA5E3C8735
Company:	Schneider Electric Industries SAS	Vendor Artifact File Name:
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Vendor Artifact Hash:
Product:	MiCOM P746	Umbrella Organization: Schneider Electric
HW Version:		Optional Reservation Test: No
SW Version:	B3	Serial Number:
Key Words:	Protection	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	kathy.ellis,bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	09/09/2016	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	TUV SUD China Ltd (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-ZE 16 09 89191 011 Schneider Electric_MiCOM P746B3_IEC618 added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

16-ZE 16 09 89191 011 Schneider Electric_MiCOM P746B3_IEC618.pdf 624 KB

07/08/2021

Herbert Falk