

# IEC 61850 Certificate - IEC 61850 Certificate #2543

## MiCOM P849 [Schneider Electric Industries SAS]

07/08/2021 04:44 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	ZE 16 08 89191 009
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	1A60B9B60E656DABAA7985D3F41744 925325D3604D1ECFFDA6E13359F10A 673B
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	Schneider Electric Industries SAS	<b>Umbrella Organization:</b>	Schneider Electric
<b>Address:</b>	35 rue Joseph Monier 92500 Rueil-Malmaison, France	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	MiCOM P849	<b>Serial Number:</b>	
<b>HW Version:</b>		<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	B1	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis,bruce.muschlitz	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	09/09/2016	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	<b>Time Activated Control:</b>	
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		
<b>Test Document:</b>			
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#### #1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-ZE 16 08 89191 009 Schneider Electric\_MiCOM P849\_IEC61850 added

#### #2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

### Files

16-ZE 16 08 89191 009 Schneider Electric\_MiCOM P849\_IEC61850.pdf 21 KB

07/08/2021

Herbert Falk