

# IEC 61850 Certificate - IEC 61850 Certificate #2548

## SICAM AK 3 [Siemens AG]

07/08/2021 04:44 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	84000072-OPE/INC 16-2310
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	43EC34D14E7793776D1B8A6A1C29C7 F53F1A50F63A3917F9976556573D8BF 476
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Siemens AG	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	IC SG EA PRO Humboldstr. 59 90459 Nuremberg Germany	<b>Umbrella Organization:</b>	
<b>Product:</b>	SICAM AK 3	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	03.04	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/17/2016	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-2310\_DNVGL\_Siemens\_SICAM\_AK3\_ClientEd2\_Certificate.pdf added

#2 - 07/09/2021 09:21 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

### Files

16-2310\_DNVGL\_Siemens\_SICAM\_AK3\_ClientEd2\_Certificate.pdf 144 KB 07/08/2021 Herbert Falk