

# IEC 61850 Certificate - IEC 61850 Certificate #2549

## SICAM AK 3 [Siemens AG]

07/08/2021 04:44 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	84000072-OPE/INC 16-2288
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	F7E108816912CA70E8FA644388AA572 DF54DF61628BE8879EB2C21A8DF43D 32B
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Siemens AG	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	IC SG EA PRO Humboldstr. 59 90459 Nuremberg Germany	<b>Umbrella Organization:</b>	
<b>Product:</b>	SICAM AK 3	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	03.04	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	kathy.ellis,bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	09/17/2016	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-2288\_DNVGL\_Siemens\_SICAM\_AK3\_ServerEd2\_Certificate.pdf added

### Files

16-2288_DNVGL_Siemens_SICAM_AK3_ServerEd2_Certificate.pdf	151 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------