

IEC 61850 Certificate - IEC 61850 Certificate #2550

MiCOM P543 [Schneider Electric]

07/08/2021 04:44 PM - Herbert Falk

Status:	Approved	Certificate Name:	132672 OPE/INC 16-2285
Priority:	Normal	Certificate Hash:	61B2A1C9D64AD951F57C5C60070686 D846A2B303BD5E66984362EB3FE262 46C3
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schneider Electric	Umbrella Organization:	Schneider Electric
Address:	35 Rue Joseph Monier 92500 Rueil Malmaison France	Optional Reservation Test:	No
Product:	MiCOM P543	Serial Number:	
HW Version:	M	Publisher Legacy Variants:	
SW Version:	D2	Publisher Preferred Rates:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	3.03	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	09/23/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-2285_DNV_GL_Schneider_P543_ServerEd1_Certificate.pdf added

#2 - 07/09/2021 09:31 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

Files

16-2285_DNV_GL_Schneider_P543_ServerEd1_Certificate.pdf

138 KB

07/08/2021

Herbert Falk