

IEC 61850 Certificate - IEC 61850 Certificate #2551

IGComms SA Server [IGrid T&D]

07/08/2021 04:44 PM - Herbert Falk

Status:	Approved	Certificate Name:	84000079-OPE/INC 16-2376
Priority:	Normal	Certificate Hash:	CD16E234FE65E838B6AD096C37698C 9E62555EC4F0D7ADB3A0FD613EEF7 E2137
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Client	Vendor Artifact Hash:	
Company:	IGrid T&D	Umbrella Organization:	
Address:	Barcelona Advanced Industry Park, C. Marie Curie, 8-14 08042 Barcelona, Spain	Optional Reservation Test:	Yes
Product:	IGComms SA Server	Serial Number:	
HW Version:	ASUS A53E-SX1121V + Win10 Home	Publisher Legacy Variants:	
SW Version:	App: 2.104.0 ; 61850: 3.21.0	Publisher Preferred Rates:	
Key Words:	Comm	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	10/07/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:44 PM - Herbert Falk

- File 16-2376_DNVGL_IGRID_IGComms_ClientEd2_Certificate.pdf added

#2 - 07/11/2021 10:08 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

