

IEC 61850 Certificate - IEC 61850 Certificate #2560

PAC-XG100 [PNC Technologies Co., Ltd.]

07/08/2021 04:45 PM - Herbert Falk

Status:	Approved	Certificate Name:	2016TS02652
Priority:	Normal	Certificate Hash:	528F9768031312E7BA07B446EB997E9 A0D887B00CC7F3675237CBE7B9A681 C0F
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	PNC Technologies Co., Ltd.	Umbrella Organization:	
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si. Gyeonggi-do, 14042 Republic of Korea	Optional Reservation Test:	No
Product:	PAC-XG100	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	1.00	Publisher Preferred Rates:	
Key Words:	Protection	Publisher Preferred Variants:	
Test Procedure Version:	3.03	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	10/31/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:45 PM - Herbert Falk

- File 2016TS02652_PNCTech_PAC-XG100_Server1.0_KERI.pdf added

Files

2016TS02652_PNCTech_PAC-XG100_Server1.0_KERI.pdf	1.16 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------