

# IEC 61850 Certificate - IEC 61850 Certificate #2561

## CoreTec - Transformer Monitoring Unit [ABB AB PPTR/AT ]

07/08/2021 04:45 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	D 16 11 90121 003
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	600B25E8D6586F4C37427F786E81393 AA540CDD863B88EED498D4A87884F D5BD
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ABB AB PPTR/AT	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Valhallavagen 2 771 80 Ludvika Sweden	<b>Umbrella Organization:</b>	
<b>Product:</b>	CoreTec - Transformer Monitoring Unit	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	2.4	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Meter, Protection	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	3.03	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	11/13/2016	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:45 PM - Herbert Falk

- File 16-D 16 11 90121 003-ABB\_CoreTec\_IEC61850Ed1-Server-Certificate.pdf added

### Files

16-D 16 11 90121 003-ABB\_CoreTec\_IEC61850Ed1-Server-Certificate.pdf 99 KB

07/08/2021

Herbert Falk