

# IEC 61850 Certificate - IEC 61850 Certificate #2562

## ETR600-FL [ENTEC Electric & Electronic Co., Ltd.]

07/08/2021 04:45 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	201STS02951
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	394E010E125854FC7B86B0CD95C73E BA0A305EAD6FCF1C64E2005BFFC45 514D7
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ENTEC Electric & Electronic Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	225-38 Choirubaekro, Bongdam-eup, Hwasung-city Gyeonggido, 445-894 Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	ETR600-FL	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	1.0.0.0	<b>Serial Number:</b>	
<b>SW Version:</b>	1.1.1.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	11/14/2016	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:45 PM - Herbert Falk

- File 2016TS02951\_ENTEC\_ETR600-FL\_Server2.0\_KERI.pdf added

### Files

2016TS02951_ENTEC_ETR600-FL_Server2.0_KERI.pdf	1.22 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------