IEC 61850 Certificate - IEC 61850 Certificate #2563

Discovery IEC 61850 Client [Grid Software Inc.]

07/08/2021 04:45 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	ZE 16 11 97810002
61850 Tested Aspects:	Client	**Certificate Hash:**	5C0499F29B00757E56E0DB208E61CC1DFBAB56B991A236EB7A11C462A7C3D9AD
Company:	Grid Software Inc.	**Vendor Artifact File Name:**	
Address:	202, 5240 - 1A St SE Calgary, AS T2H 1J1 Canada	**Vendor Artifact Hash:**	
Product:	Discovery IEC 61850 Client	**Umbrella Organization:**	
HW Version:	Lenovo Thinkpad T530	**Optional Reservation Test:**	Yes
SW Version:	1.0	**Serial Number:**	
Key Words:	Comm	**Publisher Legacy Variants:**	
Test Procedure Version:	1.0	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), Logging (B7), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	11/25/2016	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	TUV SUD Germany (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:45 PM - Herbert Falk

- File 16-ZE 16 11 97810 002-Grid Software_Discovery Client_IEC61850Ed2-Clien added

#2 - 07/11/2021 10:09 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

16-ZE 16 11 97810 002-Grid Software_Discovery Client_IEC61850Ed2.pdf	245 kB	07/08/2021	Herbert Falk