

IEC 61850 Certificate - IEC 61850 Certificate #2566

HS-CSD - Controlled Switching Device [HYOSUNG Corporation]

07/08/2021 04:45 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 2016TS03528
61850 Tested Aspects:	Server	Certificate Hash: 3424A3C5CECB5E614D191217E22715 FE6276B3C770F8FE51F44F8C068A7F A42B
Company:	HYOSUNG Corporation	Vendor Artifact File Name:
Address:	119, Mapo-daero, Mapo-gu, Seoul, Republic of Korea, 04144	Vendor Artifact Hash:
Product:	HS-CSD - Controlled Switching Device	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	1.001A	Serial Number:
Key Words:	Comm	Publisher Legacy Variants:
Test Procedure Version:	3.03	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	12/11/2016	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:45 PM - Herbert Falk

- File 2016TS03528_Hyosung_HS-CSD_Server1.0_KERI.pdf added

Files

2016TS03528_Hyosung_HS-CSD_Server1.0_KERI.pdf	2.5 MB	07/08/2021	Herbert Falk
---	--------	------------	--------------