

IEC 61850 Certificate - IEC 61850 Certificate #2570

HCCP-10 : HVDC Converter Control/Protect [HYOSUNG Corporation]

07/08/2021 04:45 PM - Herbert Falk

Status:	Approved	Certificate Name:	2016TS03572
Priority:	Normal	Certificate Hash:	1675A69C72C2BAE2F6AE7D0997121E 114736F21F2C5EADE01A0C8415B08A 39CE
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	HYOSUNG Corporation	Umbrella Organization:	
Address:	119, Mapo-daero, Mapo-gu, Seoul Republic of Korea, 04144	Optional Reservation Test:	No
Product:	HCCP-10 : HVDC Converter Control/Protect	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	1.000	Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	3.03	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	12/22/2016	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Test Document:			
Description This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:45 PM - Herbert Falk

- File 2016TS03572_Hyosung_HCCP-10_Server1.0_KERI.pdf added

Files

2016TS03572_Hyosung_HCCP-10_Server1.0_KERI.pdf	2.95 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------