

IEC 61850 Certificate - IEC 61850 Certificate #2572

SICAM A8000 CP-8000 modular device [Siemens AG]

07/08/2021 04:45 PM - Herbert Falk

| | | | |
|-------------------------------------|---|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | 84000136-OPE/INC 17-1379 |
| 61850 Edition: | Edition 2 | Certificate Hash: | 606DD8E3E0D64360720F40B467E4978 5D1139C5C066B59EEADC50D1A01CD 3AFF |
| 61850 Tested Aspects: | Client | Vendor Artifact File Name: | |
| Company: | Siemens AG | Vendor Artifact Hash: | |
| Address: | IC SG EA PRO Humboldstr. 59 90459 Nuremberg, Germany | Umbrella Organization: | |
| Product: | SICAM A8000 CP-8000 modular device | Optional Reservation Test: | Yes |
| HW Version: | 6MF21010AB100AA0EE | Serial Number: | |
| SW Version: | ET85 Rev. 03.04 | Publisher Legacy Variants: | |
| Key Words: | Comm | Publisher Preferred Rates: | |
| Test Procedure Version: | 1.0 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | bruce.muschlitz | Subscriber Preferred Variants: | |
| Approval Date: | 01/17/2017 | | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:45 PM - Herbert Falk

- File 17-1739_DNV_GL_Siemens_SICAM A8000 CP-8000 (ET85 FW)_ClientEd2_Certifi added

#2 - 07/11/2021 10:09 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

Files

17-1739_DNV_GL_Siemens_SICAM A8000 CP-8000 (ET85 FW)_ClientEd2_Certifi.pdf 07/08/2021 10:02 KB

Herbert Falk