

# IEC 61850 Certificate - IEC 61850 Certificate #2573

## SICAM A8000 CP-8000 modular device [Siemens AG]

07/08/2021 04:45 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	844000136-OPE/INC 17-1741
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	3DC250A52FA2C81D15DC2C3A109994 EBC465069A11CE2D56E5EE0B1CDC1 76AAF
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Siemens AG	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	IC SG EA PRO Humboldstr. 59 90459 Nuremberg, Germany	<b>Umbrella Organization:</b>	
<b>Product:</b>	SICAM A8000 CP-8000 modular device	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	6MF21010AB100AA0EE	<b>Serial Number:</b>	
<b>SW Version:</b>	ET85 Rev. 03.04	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Comm	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Setting Group (B4), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	01/17/2017	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:45 PM - Herbert Falk

- File 17-1741\_DNV-GL\_SIEMENS\_SICAM A8000\_ServerEd2\_Certificate.pdf added

### Files

17-1741\_DNV-GL\_SIEMENS\_SICAM A8000\_ServerEd2\_Certificate.pdf 9 KB

07/08/2021

Herbert Falk