

IEC 61850 Certificate - IEC 61850 Certificate #2574

SICAM AK 3 w/mod CP-2016 and CP-2019 [Siemens AG]

07/08/2021 04:45 PM - Herbert Falk

Status:	Approved	Certificate Name:	844000136-OPE/INC 17-1745
Priority:	Normal	Certificate Hash:	9E798A5A0073F903F819ADFC1439C8 12D43B443609445D7C1F8BD06E421C 674B
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Siemens AG	Umbrella Organization:	
Address:	IC SG EA PRO Humboldstr. 59 90459 Nuremberg, Germany	Optional Reservation Test:	No
Product:	SICAM AK 3 w/mod CP-2016 and CP-2019	Serial Number:	
HW Version:	BC2-01x--.03	Publisher Legacy Variants:	
SW Version:	SICAM AK 3 w/mod CP-2016 and CP-	Publisher Preferred Rates:	
Key Words:	Comm	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Setting Group (B4), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	01/17/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:45 PM - Herbert Falk

- File 17-1745_DNV-GL_SIEMENS_SICAM AK3_ServerEd2_Certificate.pdf added

Files

17-1745_DNV-GL_SIEMENS_SICAM AK3_ServerEd2_Certificate.pdf 87.7 KB

07/08/2021

Herbert Falk