

IEC 61850 Certificate - IEC 61850 Certificate #2575

TECON 311FS (????? 311FS) [TECON Group]

07/08/2021 04:45 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10029266-OPE/INC 16-2678
61850 Edition:	Edition 2	Certificate Hash:	262C95E26405EC934910CB3E4EE04E 93F4AB074E880D9EFE28498998147F0 28E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	TECON Group	Vendor Artifact Hash:	
Address:	3-ya Khoroshevskaya ul. 20 123298 Moscow Russian Federation	Umbrella Organization:	
Product:	TECON 311FS (????? 311FS)	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	0.6.0	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	01/18/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:45 PM - Herbert Falk

- File 16-2678_DNV-GL_TECON_311FS_ServerEd2_Certificate.pdf added

Files

16-2678_DNV-GL_TECON_311FS_ServerEd2_Certificate.pdf	91.6 KB	07/08/2021	Herbert Falk
--	---------	------------	--------------