

IEC 61850 Certificate - IEC 61850 Certificate #2577

DCR 150 DC Traction Protection Relay [GUANGZHOU BAIYUN]

07/08/2021 04:46 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2016PUCA0041
61850 Edition:	Edition 1	Certificate Hash:	7712C00D80691C66DAE7811DEB26BA 8404AD2048B5AB8E3DA9A0B0F28C47 3595
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GUANGZHOU BAIYUN	Vendor Artifact Hash:	
Address:	No. 18 South Daling Road, Shenshan, Baiyun District, Guangzhou 510406, China	Umbrella Organization:	
Product:	DCR 150 DC Traction Protection Relay	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	V1.16	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.03	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	01/19/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:46 PM - Herbert Falk

- File GUANGZHOU BAIYUN ELECTRIC EQUIPMENT CO., LTD._ver 1.16_DCR150 DC Traction Protection and Control Device_2016PUCA0041_KETOP.pdf added

Files

GUANGZHOU BAIYUN ELECTRIC EQUIPMENT CO., LTD._ver 1.16_DCR150 DC Traction Protection and Control Device_2016PUCA0041_KETOP.pdf