

IEC 61850 Certificate - IEC 61850 Certificate #2579

GRD151C-M Multifunction Relay [GUANGZHOU TOSHIBA BAIYUN]

07/08/2021 04:46 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 2016PUCA0050
61850 Tested Aspects:	Server	Certificate Hash: 7D084043029DD68FFEA9FE9357EC0E923F416F03679ED65C29C4D70EB7106F80
Company:	GUANGZHOU TOSHIBA BAIYUN	Vendor Artifact File Name:
Address:	No. 18 South Daling Road, Shenshan, Baiyun District, Guangzhou 510406, China	Vendor Artifact Hash:
Product:	GRD151C-M Multifunction Relay	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	V1.16	Serial Number:
Key Words:	Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	3.03	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	01/19/2017	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:46 PM - Herbert Falk

- File Guangzhou Toshiba Baiyun Electric Equipment Co.,Ltd._ver 1.16_ GRD151C-M Multifunction Relay_2016PUCA0050_KETOP.pdf added

Files

Guangzhou Toshiba Baiyun Electric Equipment Co.,Ltd._ver 1.16_ GRD151C-M Multifunction Relay_2016PUCA0050_KETOP.pdf	Herbert Falk
---	--------------