

IEC 61850 Certificate - IEC 61850 Certificate #2580

PQ3100 Monitoring Power Quality [Ningbo Jianlong Electron Co.,Ltd.]

07/08/2021 04:46 PM - Herbert Falk

Status:	Approved	Certificate Name:	2016PUCA0037
Priority:	Normal	Certificate Hash:	E850B848E79F397EDA1BB4843BC2E3 118C08C3C23CD4A17CA634019F43B2 AA03
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Ningbo Jianlong Electron Co.,Ltd.	Umbrella Organization:	
Address:	Beijiao Village, Yangming Street, Yuyao, Zhejiang, China	Optional Reservation Test:	No
Product:	PQ3100 Monitoring Power Quality	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	2.1.1.6	Publisher Preferred Rates:	
Key Words:	Meter	Publisher Preferred Variants:	
Test Procedure Version:	3.03	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	01/19/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:46 PM - Herbert Falk

- File Jianlong Electron_PQ3100_2.1.1.6_PQ3100 Monitoring Equipment Of Power Quality_2016PUCA0037_KETOP.pdf added

Files

Jianlong Electron_PQ3100_2.1.1.6_PQ3100 Monitoring Equipment Of Power Quality_2016PUCA0037_KETOP.pdf

Herbert Falk