

IEC 61850 Certificate - IEC 61850 Certificate #2582

KF6530 Transformer Differential Relay [Tianjin Keyvia Electric Co.Ltd.]

07/08/2021 04:46 PM - Herbert Falk

Status:	Approved	Certificate Name:	2016PUCA0045
Priority:	Normal	Certificate Hash:	84862C82A69B9E43C55FE4B3BF09B7 29D80B0B8F4253EA4C5F2A63FB59C5 237D
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Tianjin Keyvia Electric Co.Ltd.	Umbrella Organization:	
Address:	No.15 HaitaiFazhanErlu Road,Binhai Hi-tech Industrial Huayuan Development Area(Outer Ring), Tianjin, P.R.China 300392	Optional Reservation Test:	No
Product:	KF6530 Transformer Differential Relay	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	V1.4	Publisher Preferred Rates:	
Key Words:	Differential, Relay	Publisher Preferred Variants:	
Test Procedure Version:	3.03	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	01/19/2017	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:46 PM - Herbert Falk

- File Tianjin keyvia Electric Co.Ltd_V1.4_KF6530 Transformer Differential Protection Relay_2016PUCA0045_KETOP.pdf added

Files

Tianjin keyvia Electric Co.Ltd_V1.4_KF6530 Transformer Differential Protection Relay_2016PUCA0045_KETOP.pdf

Herbert Falk